



# VILLAGE OF LINDENHURST

IEPA FACILITY NO. IL0971000

## 2016

ANNUAL DRINKING WATER  
QUALITY REPORT

REPORTING PERIOD FROM  
JANUARY 1, 2016 TO DECEMBER 31, 2016

[www.lindenhurstil.org/2016waterreport](http://www.lindenhurstil.org/2016waterreport)



2301 E. Sand Lake Road • Lindenhurst, Illinois 60046 • (847) 356-8252

[www.lindenhurstil.org](http://www.lindenhurstil.org) • [mail@lindenhurstil.org](mailto:mail@lindenhurstil.org)

This report is intended to provide you with important information about your drinking water and the efforts made by the Village of Lindenhurst to provide safe drinking water. The source of drinking water used by the Village of Lindenhurst is Groundwater. For more information regarding this report contact Ms. Lynne Timmerman at 847-356-8252. Este informe contiene informacion muy importante sobre el agua que usted bebe. Traduzcalo o hable con alguien que lo entienda bien.

This year, as in years past, your tap water met all United States Environmental Protection Agency (USEPA) and Illinois Environmental Protection Agency (IEPA) drinking water health standards. We vigilantly monitor our groundwater supply and are able to report that the water department had no violation of a contaminant level or of any water quality standard in the previous year. This report summarizes the quality of water that we provided last year, including details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies.

### Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife. Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems. Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (1-800-426-4791).

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Lindenhurst cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to contact the Village Hall or attend a regularly scheduled Village Board Meeting (2nd & 4th Mondays each month at 7:00 p.m. at the Village Hall) for additional information or concerns that you may have. The source water assessment for our supply has been completed by the Illinois Environmental Protection Agency. If you would like a copy of this information, please stop by the Village Hall or contact us at 847-356-8252.

To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois Environmental Protection Agency website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

The Village uses groundwater from eight (8) wells that are located within the Village limits. These wells are drilled into sand and gravel aquifers (an aquifer is a geological formation that contains water). Residents should be aware that groundwater is considered hard and could cause white spots on fixtures, dishes, glassware, etc. Groundwater also contains iron, which may leave mineral deposits on clothes, porcelain products and may occasionally cause discolored water. Although water hardness and iron can cause aesthetic concerns with the water, it poses no adverse health effects and is safe to drink.

Based on information obtained in a Well Site Survey, published in 1989 by the Illinois EPA, nine potential sources or problem sites were identified within the survey area of Lindenhurst wells. Information provided by the Leaking Underground Storage Tank Section of the Illinois EPA indicated several additional sites with ongoing remediation which may be of concern. Based on efforts made by the Village, we have had all of the underground storage tanks removed. The Illinois EPA has determined that the Lindenhurst Community Water Supply's source water is not susceptible to contamination. This determination is based on a number of criteria including: monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system; and the available hydrogeologic data on the wells. Furthermore, in anticipation of the USEPA's proposed Ground Water Rule, the IEPA has determined that the Lindenhurst Community Water Supply is not vulnerable to viral contamination. This determination is based

upon the completed evaluation of the following criteria during the Vulnerability Waiver Process: the community's wells are properly constructed with sound integrity and proper site conditions; a hydrogeologic barrier exists which prevents pathogen movement; all potential routes and sanitary defects have been mitigated such that the source water is adequately protected; monitoring data did not indicate a history of disease outbreak; and the sanitary survey of the water supply did not indicate a viral contamination threat. Because the community's wells are constructed in a confined aquifer, which should prevent the movement of pathogens into the wells, well hydraulics were not considered to be a significant factor in the susceptibility determination. Hence, well hydraulics were not evaluated for this groundwater supply.

### Lead and Copper

Definitions: Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALG's allow for a margin of safety.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/10/2014	1.3	1.3	0.599	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

### Water Quality Test Results

Due to favorable monitoring history, aquifer characteristics, and inventory of potential sources of contamination, our water supply was issued a vulnerability waiver renewal. No monitoring for VOC's, SOC's and cyanide is required between January 1, 2014, to December 31, 2016.

Definitions: The following tables contain scientific terms and measures, some which may require explanation. A Level 1 Assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system. A Level 2 Assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions. Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety. Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG as feasible using the best available treatment technology. Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants. Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water. ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water. NA: not applicable. Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Some contaminants are sampled less frequently than once a year; as a result, not all contaminants were sampled for during the CCR calendar year. If any of these contaminants were detected the last time they were sampled for, they are included in the table along with the date that the detection occurred.

2016 Regulated Contaminants								
	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Disinfectants and Disinfection By-Products								
Chlorine	12/31/16	0.9	0.7 - 1	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)	2016	7	5.6 - 6.8	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2016	31	29.7 - 31.4	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants								
Arsenic	7/22/2015	1.3	0 - 1.3	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	7/22/2015	0.07	0.038 - 0.07	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	7/22/2015	1	0.922 - 1	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.

Sodium	7/22/2015	36	23 - 36			ppm	N	Erosion from naturally occurring deposits: Used in water softener regeneration.
The following Inorganic Contaminants are not currently regulated by the USEPA. However, the state regulates them.								
Iron	7/22/2015	0.48	0.081 - 0.48		1.0	ppm	N	Erosion of natural deposits.
Manganese	7/22/2015	5.5	1.3 - 5.5	150	150	ppb	N	Erosion of natural deposits.
Zinc	7/22/2015	0.0061	0 - 0.0061	5	5	ppm	N	Naturally occurring; discharge from metal.